



**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY
KALMANDAPAM PALAKKAD**
Telephone No - 0491 2545550, E-mail - kwater.palakkad@kwa.abn.com

Test Report

Test Report No : KWA/QCDL/PKD/1904/2026

U.L.R No: TC962826000001904F


Report Date : 26-05-2026

Customer Name & Address Palghat Lions School Koppam Palakkad-679001	1. Date of receipt	: 21-05-2026
	2. Sampling done by	: Customer
	3. UID No of Sample	: KWA/QCDL/PKD/S-1904/2026
	4. Source of sample	: Open Well (Direct)
	5. Sample description	: Clear Liquid
	6. Type of sample	: Drinking Water
	7. Purpose of test	: Commercial
	8. Sample quantity	: 100ml
	9. Test performing dates:	From 21-05-2026 To 22-05-2026

Sl. No	Parameters	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Total Coliform	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detected / 100ml	Not Detected
2	E.coli	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detected / 100ml	Not Detected

Remarks:-


NB - The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.



Analyzed by
BACTERIOLOGIST

Authorised by
BACTERIOLOGIST
KERALA WATER AUTHORITY
QCDL PALAKKAD 679001

Issue No: (G)
Issue Date: 31/03/2025
Page 1 of 1





**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY
KALMANDAPAM PALAKKAD**

Telephone No - 0491-2545550, E-mail -kwaqc.palakkad@yahoo.com

Test Report

Test Report. No : KWA/QCDL/PKD/1904/2026

ULR No.: TC968826000001904F

Report Date : 26-05-2026

Customer Name & Address Palghat Lions School Koppam Palakkad-678001	1. Date of receipt	: 21-05-2026
	2. Sampling done by	: Customer
	3. UID No.of Sample	: KWA/QCDL/PKD/S-1904/2026
	4. Source of sample	: Open Well (Direct)
	5. Sample description	: Clear Liquid
	6. Type of sample	: Drinking Water
	7. Purpose of test	: Commercial
	8. Sample quantity	: 100ml
	9. Test performing dates:	From 21-05-2026 To 22-05-2026

Sl. No	Parameters	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Total Coliforms	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detected / 100ml	Not Detected
2	E.coli	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detected / 100ml	Not Detected

Remarks:-

NB - The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.




Shajal S
Analysed by
BACTERIOLOGIST
KERALA WATER AUTHORITY
QCDL PALAKKAD-678 001

Shajal S
Authorised by
BACTERIOLOGIST
KERALA WATER AUTHORITY
QCDL PALAKKAD-678 001

* End of Report

KWA/QCDL/PKD/R No.06	Issue No. 01	Issue Date : 01/03/2025
Amend No. 02	Amend Date 29/07/2025	Page 1 of 1





**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY
KALMANDAPAM PALAKKAD**
Telephone No - 0491-2545550, E-mail - kwaqc.palakkad@yahoo.com

Test Report

Test Report No: KWA/QCDL/PKD/1904/2026		Report Date: 26-05-2026	
Customer Name & Address		1. Date of receipt : 21-05-2026	
<p align="center">Palghat Lions School Koppam Palakkad-678001</p>		2. Sampling done by : Customer	
		3. UID No. of Sample : KWA/QCDL/PKD/S-1904/2026	
		4. Source of sample : Open Well (Direct)	
		5. Sample description : Clear Liquid	
		6. Type of sample : Drinking Water	
		7. Purpose of test : Commercial	
		8. Sample quantity : 2 Litre	
		9. Test performing dates:	
		From 21-05-2026	To 22-05-2026

Sl. No.	Characteristic	Test Method	Maximum acceptable limit as per IS 10500-2012	Result
1	Acidity, mg/l	IS 3025 (Part 22) : 2024 Indicator Method	-	9

Remarks:-

NB - The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Analysed by **Alhira P.S**
TECHNICAL MANAGER
KERALA WATER AUTHORITY
QCDL PALAKKAD-678001

Authorized by **Alhira P.S**
TECHNICAL MANAGER
KERALA WATER AUTHORITY
QCDL PALAKKAD-678001

* End of Report *

KWA/QCDL/PKD-R No 0	Issue No 03	Issue Date 01/03/2025
Amend No 03	Amend Date 01/01/2026	Page 1 of 1

